ISO 9001:2000 Certified Company

MITCON CONSULTANCY SERVICES LTD.

Ref No.: LIB/VENDOR REG./2006-07 Date: November 1, 2006

To,

M/s. NIPPEN ELECTRICAL INSTRUMENTS CO.
12-A, JOY ENGG. COMPOUND,
MAROL MAROL ROAD,
ANDHERI (EAST),
MUMBAI-400 059
TEL: 2850 0581

Sub: Confirmation of Vendor Registration

Dear Sir,

We acknowledge with thanks the receipt of your Letter along with Vendor Registration Form duly filled in and the payment of Rs.2,500/- (Two Thousand Five Hundred Only) by D.D. No.419758 dated 30th October 2006 for Registration. We have noted all the details enclosed by you. We will circulate the same to the concerned departments and our clients as per their requirement. We are registering you as Authorized Vendor for Analog 7 Digital Ammeter, Voltmeter, and P.F.FREQ. Energy Meter, Multi Function Meter, CT, Shunt, Meger Earth Tester, VAF, & Randucer ETC.

"VEN/MIT-LIB/ NIPPEN ELECTRICAL INSTRUMENTS / 2006-07/21

We are enclosing the official receipt for the above payment.

Thanking you,

Yours faithfully,

LIBRARIAN
MITCON, Pune.
Encl: Receipt

Regd. Office : Kubera Chambers, Shivajinagar, Pune 411005. INDIA. Tel.: 91-020-25533309, 25534322 Fax : 91-020-25533206 Email : mitconmail@gmail.com
Pune Branch : Agriculture College Campus, Next to DIC Office, Shivajinagar, Pune 411005 Tel.: 91-020-25530308, 25530041 Fax : 91-020-25530307 Email : edtraining@rediffmail.com
Mumbai Office : Ground Floor, 'Krupanidhi', 9 Walchand Hirachand Marg, Ballard Estate, Mumbai 400 001 Tel.: 91-022-22624810 Telefax : 91-022-22612594 Email : mitcon.mumbai@gmail.com
Delhi Office : Flat No. 55 C, Block B-1A, Janak Puri, New Delhi 110058 Telefax : 91-011-25592759 Email : mitcon@gmail.com
www.mitconindia.com

MAHARASHTRA STATE ELECTRICITY TRANS C
TESTING DIVISION, KALWA

PHONE (o) 27601920
(F) 27601934

O/O The Executive Engineer
Testing Division, Kalwa
Thane Belapur Road,
At Airoli, Post Airoli Node
NEW MUMBAI 400 708

No. EE Testing Dn. KLW Tech 558 Date 09/08/05

NIPPEN,
Electrical Instruments Co.
R-A Joy Engg. Compound
Marol Maroshi Road,
Andheri(East), Mumbai 59

Sub - Performance report of NIPPEN Multifunctional Power meter model SLM-34

Dear Sir,

The NIPPEN Multifunctional meter model SLM-34 is installed in series with the existing static energy meter of 22 KV Mumbra-II feeder from June 2005 at 220 KV R.S. Kalwa.

The meter was tested & all parameters (MW, MVAR Voltage, current & P.F.) readings displayed correctly. Also errors of meter are within permissible limit.

Hence the performance of meter is satisfactory.

Thanking you.

Yours faithfully,

Executive Engineer,
EHV Testing Dn. Kalwa.